

EC-TYPE EXAMINATION CERTIFICATE (MODULE B)

Certificate no.:
MEDB00006V7
Revision no.:
2

Application of: Directive 2014/90/EU of 23 July 2014 on marine equipment (MED). This Certificate is issued by DNV SE based on the notification of the Federal Maritime and Hydrographic Agency of Germany.

This is to certify:

that the **Portable fire-extinguishing equipment for lifeboats and rescue boats**

with type designation(s)

EEC-2A1e2, EEC-2e2, EED-1, EED-2, EED-2h, EED-3, EED-4c, EED-4N, EEF-2s, EEF-2s+, EEF-6cs, EEF-6s, EEF-6s+, EEK-2s, EEK-6cs, EEK-6s, EEW-6cs, EEW-6s

issued to

Eversafe Extinguisher Sdn. Bhd.
Subang Jaya, Malaysia

is found to comply with the Implementing Regulation (EU) 2024/1975 for
Item no. **MED/3.38 (Row 2 of 2)**

according to the following requirements:

SOLAS 74 Reg. III/34, IMO Res. A.951(23), IMO Res. MSC.36(63)-(1994 HSC Code) 8, IMO Res. MSC.48(66)-(LSA Code) I, IMO Res. MSC.48(66)-(LSA Code) IV, IMO Res. MSC.48(66)-(LSA Code) V, IMO Res. MSC.97(73)-(2000 HSC Code) 8, SOLAS 74 Reg. III/4, SOLAS 74 Reg. X/3


Further details of the equipment and conditions for certification are given overleaf.

Date of issue: **2025-08-20**

Expiry date: **2030-08-19**

DNV local unit:
Kuala Lumpur Verification

Approval Engineer:
Meike Grabau



Notified Body
no.: **0098**



for DNV SE

Digitally Signed By:

Christine Mydlak-Röder

Christine Mydlak-Röder
Head of Notified Body

The mark of conformity may only be affixed to the above type approved equipment and a Manufacturer's Declaration of Conformity issued when the production-surveillance module (D, E or F) of Annex B of the MED is fully complied with and controlled by a written inspection agreement with a Notified Body. The product liability rests with the manufacturer or his representative in accordance with Directive 2014/90/EU.

This certificate is valid for equipment, which is conform to the approved type. The manufacturer shall inform DNV SE of any changes to the approved equipment. This certificate remains valid unless suspended, withdrawn, recalled or cancelled.

Should the specified regulations or standards be amended during the validity of this certificate, the product is to be re-approved before being placed on board a vessel to which the amended regulations or standards apply.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to USD 300 000.

Product description

Portable fire extinguishers for lifeboats and rescue boats with designation given in the appendix to this certificate.

Please see Appendix: Product Description

Application/Limitation

Extinguishers of size less than 9 L foam, 5 kg CO₂ or 5 kg powder may only be used when accepted by the Flag Administration.

The portable extinguisher shall be of a size in accordance with FSS Code, Ch. 4, except that smaller extinguishers may be used for lifeboats and rescue boats if their combined capacity equals or exceeds the requirements of that Code.

For water based extinguishers of types EEf-2s, EEf-2s+, EEf-6cs, EEf-6s, EEf-6s+, EEK-2s, EEK-6cs, EEK-6s, EEW-6cs and EEW-6s a Dielectric Test according to EN 3-7 item 9 has been performed showing that this product is suitable for use on live electrical equipment up to 1,000 V at a distance of 1 m.

Each product is to be supplied with its manual for installation and use.

Type Examination documentation

Tests carried out

Tested according to EN 3-7, EN 3-8 and EN 3-9.

Marking of product

The product is to be marked with name and address of manufacturer, type designation, the MED Mark of Conformity (see first page) and to be in accordance with EN 3-7, Ch. 16.

APPENDIX

Product Description

Certificate no.:
MEDB00006V7
 Revision no.:
2

Products designation:

Type	Fire rating	Temperature range [°C]	Extinguishing medium	Charge size	Assembly drawing No.
EEC-2Ale2	34B	-20 to +60	CO ₂	2 kg	71PWM-EEE-17-002Z-E
EEC-2e2	34B	-20 to +60	CO ₂	2 kg	71PWM-EEE-17-002A-E
EED-1	5A, 34B	-20 to +60	ABC powder	1 kg	71PWM-EEE-10-001A-E
EED-2	13A, 55B	-20 to +60	ABC powder	2 kg	71PWM-EEE-10-002A-E
EED-2h	13A, 70B	-20 to +60	ABC powder	2 kg	71PWM-EEE-10-002H-E
EED-3	13A, 89B	-20 to +60	ABC powder	3 kg	71PWM-EEE-10-003F-E
EED-4c	21A, 89B	-20 to +60	ABC powder	4 kg	71PWM-EEE-30-004A-E
EED-4N	21A, 113B	-20 to +60	ABC powder	4 kg	71PWM-EEE-10-004A-E
EEF-2s	5A, 34B	+5 to +60	6% AFFF (FF216)	2 L	71PWM-EEE-15-002A-E, Issue 01R1
EEF-2s+	5A, 34B	-5 to +60	6% AFFF (FF216) 10% Antifreeze	2 L	71PWM-EEE-15-002A+K, Issue 01R1
EEF-6cs	13A, 144B	+5 to +60	6% AFFF (FF216)	6 L	71PWM-EEE-35-006A-E, Issue 01R1
EEF-6s	13A, 144B	+5 to +60	6% AFFF (FF216)	6 L	71PWM-EEE-15-006A-E, Issue 01R1
EEF-6s+	13A, 144B	-5 to +60	6% AFFF (FF216) 10% Antifreeze	6 L	71PWM-EEE-15-006A+K, Issue 01R1
EEF-2s	5A, 34B	+5 to +60	6% AFFF (FF216-C6)	2 L	71PWM-EEE-15-002A-E, Issue 01R1
EEF-2s+	5A, 34B	-5 to +60	6% AFFF (FF216-C6) 10% Antifreeze	2 L	71PWM-EEE-15-002A+K, Issue 01R1
EEF-6cs	13A, 144B	+5 to +60	6% AFFF (FF216-C6)	6 L	71PWM-EEE-35-006A-E, Issue 01R1
EEF-6s	13A, 144B	+5 to +60	6% AFFF (FF216-C6)	6 L	71PWM-EEE-15-006A-E, Issue 01R1
EEF-6s+	13A, 144B	-5 to +60	6% AFFF (FF216-C6) 10% Antifreeze	6 L	71PWM-EEE-15-006A+K, Issue 01R1
EEK-2s	5A, 5F	0 to +60	Wet chemical	2 L	71PWM-EEE-16-002A-E
EEK-6cs	8A, 75F	0 to +60	Wet chemical	6 L	71PWM-EEE-36-006A-E
EEK-6s	8A, 75F	0 to +60	Wet chemical	6 L	71PWM-EEE-16-006A-E
EEW-6cs	13A	+5 to +60	Water	6 L	71PWM-EEE-34-006A-E
EEW-6s	13A	+5 to +60	Water	6 L	71PWM-EEE-14-006A-E

APPENDIX

Test results (as per the applicable IMO MEPC resolution)

Certificate no.:
MEDB00006V7
Revision no.:
2

Type Examination documentation

Type	Manual	Test report		
		EN 3-7:2004 +A1:2007	EN 3-8:2006 +A1:2007	EN 3-9:2006 +A1:2007
EEC-2Ale2	OIS-SPT-EEC(MED)	2244/8150392a2 Model EEC-2Ale2 Issue 2	N/A	285/7146036-5
EEC-2e2	OIS-SPT-EEC(MED)	2244/8150392a2 Model EEC-2e2 Issue 2	N/A	285/7146036-5
EED-1	OIS-SPT-EED(MED)	2244/7945292 Model EED-1	285/7146036-4	N/A
EED-2	OIS-SPT-EED(MED)	2244/7945292 Model EED-2	285/7146036-4	N/A
EED-2h	OIS-SPT-EED(MED)	2244/8150392 Model EED-2h	285/7146036-4	N/A
EED-3	OIS-SPT-EED(MED)	2244/8150392 Model EED-3	285/7146036-4	N/A
EED-4c	OIS-COT-EED(MED)	2244/8150392a2 Model EED-4c Issue 2	285/7146036-4	N/A
EED-4N	OIS-SPT-EED(MED)	2244/8150392a2 Model EED-4N Issue 2	285/7146036-4	N/A
EEF-2s	OIS-SPT-EEF(MED)	2244/8150392 Model EEF-2s	285/7146036-4	N/A
EEF-2s+	OIS-SPT-EEF(MED)	2244/8150392 Model EEF-2s+	285/7146036-4	N/A
EEF-6cs	OIS-COT-EEF(MED)	2244/8150392 Model EEF-6cs	285/7146036-4	N/A
EEF-6s	OIS-SPT-EEF(MED)	2244/8150392 Model EEF-6s	285/7146036-4	N/A
EEF-6s+	OIS-SPT-EEF(MED)	2244/8150392 Model EEF-6s+	285/7146036-4	N/A
EEF-2s	OIS-SPT-EEF(MED)	2244/8150392 Model EEF-2s 9732178 (1 of 2) Model: EEF2S+ 9732178 (2 of 2) Model: EEF6S+ Issue 2 9732226 (1 of 1) Model: MFM-45	285/7146036-4	N/A
EEF-2s+	OIS-SPT-EEF(MED)	9732178 (1 of 2) Model: EEF2S+	285/4349809	N/A
EEF-6cs	OIS-COT-EEF(MED)	2244/8150392 Model EEF-6cs 9732178 (1 of 2) Model: EEF2S+ 9732178 (2 of 2) Model: EEF6S+ Issue 2 9732226 (1 of 1) Model: MFM-45	285/7146036-4	N/A
EEF-6s	OIS-SPT-EEF(MED)	2244/8150392 Model EEF-6s 9732178 (1 of 2) Model: EEF2S+ 9732178 (2 of 2) Model: EEF6S+ Issue 2 9732226 (1 of 1) Model: MFM-45	285/7146036-4	N/A
EEF-6s+	OIS-SPT-EEF(MED)	9732178 (2 of 2) Model: EEF6S+ Issue 2	285/7034920	N/A
EEK-2s	OIS-SPT-EEK(MED)	2244/8150392 Model EEK-2s Issue 2	285/7146036-4	N/A
EEK-6cs	OIS-COT-EEK(MED)	2244/8150392a2 Model EEK-6cs Issue 2	285/7146036-4	N/A
EEK-6s	OIS-SPT-EEK(MED)	2244/8150392a2 Model EEK-6s Issue 2	285/7146036-4	N/A
EEW-6cs	OIS-COT-EEW(MED)	2244/8150392 Model EEW-6cs	285/7146036-4	N/A
EEW-6s	OIS-SPT-EEW(MED)	2244/8150392 Model EEW-6s	285/7146036-4	N/A