

Kitemark™ Certificate

This is to certify that:

Eversafe Extinguisher Sdn Bhd
Lot 878, Jalan Subang 9,
Taman Perindustrian Subang,
Subang Jaya
Selangor
47500
Malaysia

Holds Certificate Number:

KM 544838

In respect of:

BS EN 1866-1:2007
Mobile Fire Extinguishers

This issues the right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.



For and on behalf of BSI:

Shahm Barhom, Group Product Certification Director

First Issued: 2009-11-02

Latest Issue: 2025-02-24

Effective Date: 2025-02-24

Expiry Date: 2025-12-31



Page: 1 of 2

Kitemark™ Certificate

No. KM 544838

Model No.	Description
MPM-25, CR-MPM-25	25 kg ABC powder, stored, pressure. Fire rating A rated & IB.
MPM-50, CR-MPM-50	50 kg ABC powder, stored, pressure. Fire rating A rated & IIB.
MPG-25, CR-MPG-25	25 kg ABC powder, cartridge operated. Fire rating A rated & IB.
MPG-50, CR-MPG-50	50 kg ABC powder, cartridge operated. Fire rating A rated & Type IIB.
MFM-45, CR-MFM-45	45 litre foam, stored pressure. Fire rating A rated & IIIB.
MFM-135, CR-MFM-135	135 litre foam, stored pressure. Fire rating A rated & IVB.
MFG-45, CR-MFG-45	45 litre foam, cartridge operated. Fire rating A rated & IIIB.
MFG-135, CR-MFG-135	135 litre foam, cartridge operated. Fire rating A rated & IVB.
MFG-150, CR-MFG-150	150 litre foam, cartridge operated. Fire rating A rated & IVB.
MCO-10, CR-MCO-10	10 kg carbon dioxide. Fire rating 70B.
MCO-10T, CR-MCO-10T	20 kg carbon dioxide. Fire rating 89B.
MCO-20, CR-MCO-20	20 kg carbon dioxide. Fire rating 89B.

All the above products are certified to BS EN 1866-1:2007.

Note. CR prefix indicates additional corrosion resistant model variant.

The above mobile fire extinguisher models falling within the scope of this certificate may be marketed under the following brand names:

FireSafe
Red Panther

First Issued: 2009-11-02

Latest Issue: 2025-02-24

Effective Date: 2025-02-24

Expiry Date: 2025-12-31

Page: 2 of 2

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.